


NOTES:

- 1. ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY—TYPE, CLASS
 AA, ENCAPSULATED NEMA 12 ENCLOSED
 FOR INDOOR / DUSTPROOF USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.



= H1 = H2 = H3

APPROXIMATE DIMENSIONS (INCHES)

KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
7.5	15.25	12.38	9.00	8.50	11.25		3/8-16	0.437" x 0.750"	N10	145	N/A	LEADs

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS

APPROVAL

RECORD

OTHER

					,	□OTHER		
PRIMARY VOLTAGE	208-240	CUST.	XXXXXXXX					
SECONDARY VOLTAGE	230	JOB						
TEMPERATURE RISE IN °C	115	CATALOG						
WINDINGS & TERMINALS	ALUMINUM X COPPER	NOTE	NOTE IMPORTED MACHINERY (HOT, NEU, GRD)					
FREQUENCY IN HERTZ	60	BY	ENG. LOG.	TITLE	1-PHASE, 600 VOLT CLASS ISOLATION			
PRIMARY TAPS	NONE	DATE						
DO	A CEDIDON.	REV	MFG. LOG.	DWG. NO.				
12 01	OVERTRAIN.	DATE:	DWG. FILE		NF905L7500			