



NOTES:

- 1. ALL UNITS ARE CUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- TRANSFORMERS ARE DRY—TYPE, CLASS AA, ENCAPSULATED NEMA 1 ENCLOSED FOR INDOOR USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED
- UPON A 40°C AMBIENT ENVIRONMENT.
 5. MAINTAIN 1" CLEARANCE FROM ALL
 LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.





TERMINAL VIEW

APPROXIMATE DIMENSIONS (INCHES)

KVA	А	В	С	D	E	F	HARDWARE	MTG SLOTS	ENCLOSURE	lbs.	WEATHER' SHIELD	TERMINAL TYPE
3.0	15.25	12.38	9.00	8.50	11.25		3/8-16	0.437" x 0.750"	N10	125	N/A	TBs

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS

X APPROVAL

□ RECORD

□ OTHER

,						`	<u> </u>		
PRIMARY VOLTAGE	380 DEI	LTA	CUST.	XXXXXXX					
SECONDARY VOLTAGE	220Y/1	27	JOB						
TEMPERATURE RISE IN °C	115		CATALOG						
WINDINGS & TERMINALS	☐ ALUMINUM	COPPER	NOTE	XXXXXXX					
FREQUENCY HERTZ	50/60		BY	ENG. LOG.	TITLE	•	600 VOLT	CLASS	
PRIMARY TAPS			DATE		ISOLATION DRY TYPE TRANSFORMER				
			REV	MFG. LOG.	DWG. NO.				
-POVVERTRAN-			DATE:	DWG. FILE		3EF197FST3			