





TYPICAL WIRING DIAGRAM


## NOTES:

1. ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, VENTILATED NEMA 2 ENCLOSED FOR INDOOR USE.
3. TRANSFORMERS ARE FLOOR MOUNTED.
4. AVAILABLE ACCESSORIES FOR THIS UNIT:  
A) OUTDOOR WEATHERSHIELD KIT
5. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
6. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
7. PAINT COLOR IS ANSI #61.



FRONT VIEW

SIDE VIEW



TERMINAL DETAILS

## APPROXIMATE DIMENSIONS ( INCHES )

| KVA   | A     | B     | C     | D     | E     | F    | G     | H    | J    | K     | ENCLOSURE | lbs. | WEATHER SHIELD | TERMINAL TYPE |
|-------|-------|-------|-------|-------|-------|------|-------|------|------|-------|-----------|------|----------------|---------------|
| 175.0 | 51.00 | 36.00 | 30.50 | 34.25 | 27.25 | 6.00 | 10.00 | 1.00 | 9.00 | 34.63 | 3PT-225K  | 1320 | WS-12A         | BUSBAR        |

\* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE )

DRAWINGS  
☒ APPROVAL  
☐ RECORD  
☐ OTHER

|                        |                                                                              |          |                                                                    |
|------------------------|------------------------------------------------------------------------------|----------|--------------------------------------------------------------------|
| PRIMARY VOLTAGE        | 208 DELTA                                                                    | CUST.    | XXXXXXXXXX                                                         |
| SECONDARY VOLTAGE      | 460Y/266                                                                     | JOB      |                                                                    |
| TEMPERATURE RISE IN °C | 150                                                                          | CATALOG  |                                                                    |
| WINDINGS & TERMINALS   | <input checked="" type="checkbox"/> ALUMINUM <input type="checkbox"/> COPPER | NOTE     | XXXXXXX                                                            |
| FREQUENCY IN HERTZ     | 60                                                                           | BY       | ENG. LOG.                                                          |
| PRIMARY TAPS           | 198, 218                                                                     | DATE     |                                                                    |
|                        |                                                                              | REV      | MFG. LOG.                                                          |
|                        |                                                                              | DATE:    | DWG. FILE                                                          |
|                        |                                                                              | TITLE    | 3-PHASE, 600 VOLT CLASS<br>DRIVE ISOLATION<br>DRY TYPE TRANSFORMER |
|                        |                                                                              | DWG. NO. | 3PTN384-175K-DIT                                                   |

POWERTRAN