






TYPICAL WIRING DIAGRAM

## NOTES:


1. ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, VENTILATED, OPEN-STYLE ASSEMBLY FOR INDOOR/CONTROL PANEL USE.
3. TRANSFORMER ARE BASE MOUNTED.
4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.



FRONT VIEW



SIDE VIEW



TERMINAL VIEW

## APPROXIMATE DIMENSIONS ( INCHES )

| KVA | A    | B    | C    | D    | E    | 2-POLE PRIMARY FUSE BLOCK | PRIMARY COVER | SECONDARY COVER | HARDWARE | (4) MTG SLOTS   | STEEL  | STACK | WEIGHT |
|-----|------|------|------|------|------|---------------------------|---------------|-----------------|----------|-----------------|--------|-------|--------|
| 1.0 | 7.50 | 5.25 | 6.25 | 5.25 | 4.38 | INCLUDED                  | INCLUDED      | INCLUDED        | 1/4-20   | 0.250" x 0.562" | EI-175 | 4.12  | 28     |

DRAWINGS  
☒ APPROVAL  
☐ RECORD  
☐ OTHER

|                                                            |                                                                              |           |                |
|------------------------------------------------------------|------------------------------------------------------------------------------|-----------|----------------|
| PRIMARY VOLTAGE                                            | 240 x 480                                                                    | CUST.     | XXXXXXXX       |
| SECONDARY VOLTAGE                                          | 120 x 240                                                                    | JOB       |                |
| TEMPERATURE RISE IN °C                                     | 55                                                                           | CATALOG   |                |
| WINDINGS & TERMINALS                                       | <input type="checkbox"/> ALUMINUM <input checked="" type="checkbox"/> COPPER | NOTE      | XXXXXXXX       |
| FREQUENCY HERTZ                                            | 50/60                                                                        | BY        | ENG. LOG.      |
| PRIMARY TAPS                                               | NONE                                                                         | DATE      | TITLE          |
| 1-PHASE, 600 VOLT CLASS<br>CONTROL<br>DRY TYPE TRANSFORMER |                                                                              |           |                |
| REV                                                        |                                                                              | MFG. LOG. | DWG. NO.       |
| DATE:                                                      |                                                                              | DWG. FILE | A134MT1000-2FB |