






TYPICAL WIRING DIAGRAM

## NOTES:


1. ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, VENTILATED, OPEN-STYLE ASSEMBLY FOR INDOOR/CONTROL PANEL USE.
3. TRANSFORMER ARE BASE MOUNTED.
4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.



FRONT VIEW



SIDE VIEW



TERMINAL VIEW

## APPROXIMATE DIMENSIONS ( INCHES )

| KVA | A    | B    | C    | D    | E    | F    | G    | HARDWARE | (4) MTG SLOTS   | STEEL  | STACK | WEIGHT | TERMINALS |
|-----|------|------|------|------|------|------|------|----------|-----------------|--------|-------|--------|-----------|
| 2.0 | 6.50 | 6.38 | 7.75 | 4.63 | 5.31 | ---- | ---- | 1/4-20   | 0.250" x 0.562" | EI-212 | 3.50  | 45     | SCREW TBs |

\* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE )

DRAWINGS  
☒ APPROVAL  
☐ RECORD  
☐ OTHER

|                                                        |                                                                              |           |             |
|--------------------------------------------------------|------------------------------------------------------------------------------|-----------|-------------|
| PRIMARY VOLTAGE                                        | 277                                                                          | CUST.     | XXXXXXXX    |
| SECONDARY VOLTAGE                                      | 120                                                                          | JOB       |             |
| TEMPERATURE RISE IN °C                                 | 115                                                                          | CATALOG   |             |
| WINDINGS & TERMINALS                                   | <input type="checkbox"/> ALUMINUM <input checked="" type="checkbox"/> COPPER | NOTE      | XXXXXXXX    |
| FREQUENCY IN HERTZ                                     | 60                                                                           | BY        | ENG. LOG.   |
| PRIMARY TAPS                                           | NONE                                                                         | DATE      | TITLE       |
| 1-PHASE, 600 VOLT CLASS ISOLATION DRY TYPE TRANSFORMER |                                                                              |           |             |
| REV                                                    |                                                                              | MFG. LOG. | DWG. NO.    |
| DATE:                                                  |                                                                              | DWG. FILE | F082FST2000 |

POWERTRAN