






TYPICAL WIRING DIAGRAM

NOTES:

- 1. ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
- 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, ENCAPSULATED NEMA 12 ENCLOSED FOR INDOOR / DUSTPROOF USE.
- 3. TRANSFORMERS ARE WALL / MACHINE MOUNTABLE VIA THE ATTACHED BRACKETS.
- 4. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
- 5. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
- 6. PAINT COLOR IS RAL# 7042.



FRONT VIEW



SIDE VIEW



TERMINAL VIEW

APPROXIMATE DIMENSIONS ( INCHES )

| KVA | A     | B     | C    | D    | E     | F    | HARDWARE | MTG SLOTS       | ENCLOSURE | lbs. | WEATHER SHIELD | TERMINAL TYPE |
|-----|-------|-------|------|------|-------|------|----------|-----------------|-----------|------|----------------|---------------|
| 5.0 | 15.25 | 12.38 | 9.00 | 8.50 | 11.25 | ---- | 3/8-16   | 0.437" x 0.750" | N10       | 135  | N/A            | LEADs         |

\* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY ( IF APPLICABLE )

DRAWINGS

☒ APPROVAL

☐ RECORD

☐ OTHER

|                        |                                                                              |          |            |
|------------------------|------------------------------------------------------------------------------|----------|------------|
| PRIMARY VOLTAGE        | 277                                                                          | CUST.    | XXXXXXXX   |
| SECONDARY VOLTAGE      | 120                                                                          | JOB      |            |
| TEMPERATURE RISE IN °C | 115                                                                          | CATALOG  |            |
| WINDINGS & TERMINALS   | <input type="checkbox"/> ALUMINUM <input checked="" type="checkbox"/> COPPER | NOTE     | XXXXXXXX   |
| FREQUENCY IN HERTZ     | 60                                                                           | BY       | ENG. LOG.  |
| PRIMARY TAPS           | NONE                                                                         | DATE     |            |
| POWERTRAN              |                                                                              | REV      | MFG. LOG.  |
|                        |                                                                              | DATE:    | DWG. FILE  |
|                        |                                                                              | DWG. NO. | NF082L5000 |