



- ## NOTES:
1. ALL UNITS ARE cUL LISTED & DESIGNED ACCORDANCE WITH INDUSTRY STANDARDS.
 2. TRANSFORMERS ARE DRY-TYPE, CLASS AA, VENTILATED NEMA 2 ENCLOSED FOR INDOOR USE.
 3. TRANSFORMERS ARE FLOOR MOUNTED.
 4. AVAILABLE ACCESSORIES FOR THIS UNIT:
 - A) OUTDOOR WEATHERSHIELD KIT
 - B) WALL MOUNTING BRACKETS
 5. TRANSFORMERS ARE CONSTRUCTED BASED UPON A 40°C AMBIENT ENVIRONMENT.
 6. MAINTAIN 1" CLEARANCE FROM ALL LIVE PARTS.
 7. PAINT COLOR IS ANSI #61.



KVA	A	B	C	D	E	F	G	H	J	K	ENCLOSURE	lbs.	WEATHER SHIELD	TERMINAL TYPE
300.0	43.00	28.50	23.50	26.63	20.25	6.00	6.00	1.00	5.75	27.63	3PT-112K	525	WS-18	BUSBAR

* ELECTROSTATIC SHIELD GROUNDED TO TRANSFORMER CASE AT FACTORY (IF APPLICABLE)

DRAWINGS
☒ APPROVAL
☐ RECORD
☐ OTHER

INPUT VOLTAGE	480	DIVISION		
OUTPUT VOLTAGE	415Y/240	JOB		
TEMPERATURE RISE IN °C	150	CATALOG		
WINDINGS & TERMINALS	☒ ALUMINUM ☐ COPPER	NOTE		
FREQUENCY IN HERTZ	60	BY	ENG. LOG.	TITLE 3-PHASE, 600 VOLT CLASS AUTO DRY TYPE TRANSFORMER
OUTPUT TAPS	456, 504	DATE		
		REV	MFG. LOG.	DWG. NO. 3PT578PA300
		DATE:	DWG. FILE	